



Exact Scientific Services, Inc.

Water Chemical Analysis

1355 Pacific Place
Suite 101
Ferndale, WA 98248

Phone: (360) 733-1205
Fax: (888) 818-2978
Email: lab@exactscientific.com

174 03524

Sample: Saratoga WD S05 = wells 3 & 4

Client: King Water Company

PO Box 2243

Oak Harbor, WA 98277

Phone: (360) 678-5336

Email: cerickson@nwnaturalwaterservices.com

Invoice Number: 24-00997

P.O. Number:

Report Date: 1/19/2024

Approved By:

PWS Information

Date Collected: 1/16/2024

Sample Purpose: Investigative

Sample Type: Post Treatment/Finished Water Sample

Sample Composition: Samples from a single source

Sample Collection: Flowing

Suitability: Yes

Sample Collected by:

System Group Type: A

County: ISLAND

Source Number: 5

Date Received: 1/16/2024

Date Analyzed: 1/17/2024

System Number: 76300

System Name: SARATOGA WATER DISTRICT

Lab #: 03524		Sample: Saratoga WD S05 = wells 3 & 4						
DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
EPA Regulated								
4	ARSENIC	0.0031	mg/L	0.001	0.010	0.010	200.8_As	KN

MCL = (Maximum Contaminant Level) allowed by the State of Washington. OT = Out of Hold Time RR = Revised Result

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) indicates the analyte was below the detection limit.

174 03524