Portland, OR Microbiology/Chemistry (c) 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802 Corvallis, OR Microbiology/Chemistry (d) 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e) 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: King Water Company-NW Natural Water Sevices Reference Number: 24-19156

> 107 S Main St Project: SARATOGA 76300

Coupeville, WA 98239

ANALYTICAL

Date Collected: 6/12/24 10:00 Field ID: 76300

System ID Number: 76300 System Group Type: A Lab Number: 046-37287 System Name: SARATOGA WATER DISTRICT

Sample Location: Saratoga WK2 County: ISLAND

Sample Purpose: C - Compliance Source Number: 96 - Blended Sample

Sample Composition: Blended Sample Multiple Sources:

Approved by: anp Date Received: 7/2/24 Authorized by: Report Date: 7/17/24

Sample Type: D - Drinking Water

Lawrence J Henderson, PhD Sampled By: Josiah K Director of Laboratories, Vice President Sampler Phone:

Sample Comment:

| | | | | | | Sample Comment. | | | | | | |
|------|---------------|---------|-------|-------|---------|-----------------|---------|--------|-----|----------|---------|--|
| DOH# | ANALYTES | RESULTS | UNITS | SRL | Trigger | MCL | Analyst | METHOD | Lab | Analyzed | COMMENT | |
| | EPA Regulated | | | | | | | | | | | |
| 4 | ARSENIC | 0.0102 | mg/L | 0.001 | | 0.010 | bi | 200.8 | а | 07/12/24 | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | 1 | |

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank

MCL value indicates a level is not currently established.

Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.

ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).