



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: King Water Company-NW Natural Water Services
107 S Main St
Coupeville, WA 98239

Reference Number: 24-16895
Project: 763000 - SARATOGA WATER DISTRICT

Date Collected: 6/7/24 12:20
System ID Number: 763000
Lab Number: 046-32024
Sample Location: Entry Point
Sample Purpose: C - Compliance
Sample Composition:

Approved by: anp

Authorized by:

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Field ID: 763000
System Group Type: A
System Name: SARATOGA WATER DISTRICT
County: ISLAND
Source Number:
Multiple Sources:
Date Received: 6/11/24
Report Date: 6/20/24
Sample Type: D - Drinking Water
Sampled By: Josiah Kumm
Sampler Phone: 3606329782

Sample Comment:

| DOH# | ANALYTES | RESULTS | UNITS | SRL | Trigger | MCL | Analyst | METHOD | Lab | Analyzed | COMMENT |
|------|---------------------------------|---------------|-------|-------|---------|--------------|---------|--------|-----|----------|---------|
| 4 | EPA Regulated ARSENIC | 0.0117 | mg/L | 0.001 | | 0.010 | bj | 200.8 | a | 06/18/24 | |

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.

Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.

ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.

FORM: IOC_ST