



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802


Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: King Water Company-NW Natural Water Services
107 S Main St
Coupeville, WA 98239

Reference Number: 24-27098
Project: Saratoga 763000

Date Collected: 8/28/24 10:16
System ID Number: 763000
Lab Number: 046-52398
Sample Location: After Filter
Sample Purpose: C - Compliance
Sample Composition: Single Source
Approved by: anp
Authorized by: 
Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Field ID: 763000
System Group Type: A
System Name: SARATOGA WATER DISTRICT
County: ISLAND
Source Number: 05
Multiple Sources:
Date Received: 9/10/24
Report Date: 9/23/24
Sample Type: A - After treatment
Sampled By: Josiah Kumm
Sampler Phone: 360-632-5782

Sample Comment:

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
4	EPA Regulated ARSENIC	0.0047	mg/L	0.001		0.010	bj	200.8	a	09/18/24	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.

Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.

ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.

FORM: IOC_ST