Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)

Portland, OR Microbiology/Chemistry (c) 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR *Microbiology/Chemistry (d)* 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR *Microbiology* (e) 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Page 1 of 1

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: King Water Company-NW Natural Water Sevices Reference Number: 24-34968

107 S Main St

Coupeville, WA 98239

System Name: SARATOGA WATER DISTRICT

System ID Number: 763000

DOH Source Number: 00 - Distribution Sample (Bacteria)

Sample Type: D - Drinking Water Sample Purpose: C - Compliance Sample Location: 3772 Bells Beach Rd

County: Island Sampled By: Josiah

Sampler Phone:

Repeat Sample Number:

Lab Number: 164-67368

Field ID:

Date Collected: 11/19/24 11:47

Project: SARATOGA WATER DISTRICT

Date Received: 11/19/24

Date Set: 11/19/24 18:17 Date Analyzed: 11/20/24 13:57

Report Date: 11/25/24 Comment: Cl2: 0.88 Approved By: ckk,mlh

Authorized by:

Ceann K Knox Lab Manager, Bellingham

		Lab Mariagor, Domingham						
DOH#	PARAMETER	RESULT	Qualifier*	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	jln	SM9223 B	m_241119b	
3	E. COLI	Absent		per 100mL		SM9223 B	m_241119b	

If the sample is unsatisfactory you can get information on well disinfection at Washington State Department of Health:

WA DOH: https://doh.wa.gov/community-and-environment/drinking-water/disinfection

NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.