

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: King Water Company-NW Natural Water Services
107 S Main St
Coupeville, WA 98239

Reference Number: 24-38070

Project: King Water Services - Saratoga

System Name: SARATOGA WATER DISTRICT
System ID Number: 763000
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: 2742 Center St
County: Island
Sampled By: ND
Sampler Phone:

Repeat Sample Number:
Lab Number: 164-73315
Field ID: Bacteria
Date Collected: 12/19/24 12:55
Date Received: 12/20/24
Date Set: 12/20/24 17:59
Date Analyzed: 12/21/24 15:58
Report Date: 12/26/24
Comment: Cl2: 0.30
Approved By: jln

Authorized by: 

Jessica L Nunamaker
Microbiologist/QA Officer

DOH#	PARAMETER	RESULT	Qualifier*	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	mlp	SM9223 B	m_241220a	
3	E. COLI	Absent		per 100mL		SM9223 B	m_241220a	

If the sample is unsatisfactory you can get information on well disinfection at Washington State Department of Health:

WA DOH: <https://doh.wa.gov/community-and-environment/drinking-water/disinfection>

NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

*If data qualifiers are present, see accompanying Qualifier Definition report.