

Burlington, WA (a) 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Environment Testing Bellingham, WA Microbiology (b) 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Edge Analytical

503.682.7802 e Cr Ste A2 - Wilso Ile. OR 97070 Corvallis, OR Microbiology/Chemistry (d) 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946 Bend, OR Microbiology (e) 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

Portland, OR Microbiology/Chemistry (c)



INORGANIC COMPOUNDS (IOC) REPORT

Client Name: King Water Company-NW Natural Water Sevices 107 S Main St Coupeville, WA 98239

> Date Collected: 12/30/24 10:46 System ID Number: 763000 Lab Number: 046-73867 Sample Location: Saratoga Sample Purpose: C - Compliance Sample Composition: Single Source Approved by: anp Authorized by:

Nenu

Lawrence J Henderson, PhD Director of Laboratories, Vice President Reference Number: 24-38408 Project: Saratoga Water District 763000

Field ID:	763000
System Group Type:	A
System Name:	SARATOGA WATER DISTRICT
County:	Island
Source Number:	05
Multiple Sources:	
Date Received:	12/31/24
Report Date:	1/8/25
Sample Type:	D - Drinking Water
Sampled By:	Josiah
Sampler Phone:	

Sample Comment:

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT	
4	EPA Regulated ARSENIC	0.0166	mg/L	0.001		0.010	bj	200.8	а	01/03/25		
	1	1	1			1						

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established. Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.

ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above. FORM: IOC_ST