

## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: King Water Company-NW Natural Water Services  
107 S Main St  
Coupeville, WA 98239

Reference Number: 25-04360

Project: King Water Services - Saratoga

System Name: SARATOGA WATER DISTRICT  
System ID Number: 763000  
DOH Source Number: 00 - Distribution Sample (Bacteria)  
Sample Type: D - Drinking Water  
Sample Purpose: C - Compliance  
Sample Location: 3759 Saratoga  
County: Island  
Sampled By: JD  
Sampler Phone:

Repeat Sample Number:  
Lab Number: 164-09062  
Field ID: Saratoga  
Date Collected: 2/11/25 11:58  
Date Received: 2/11/25  
Date Set: 2/11/25 18:47  
Date Analyzed: 2/12/25 16:08  
Report Date: 2/14/25  
Comment: Cl2: 0.12  
Approved By: jln,mlh

Authorized by:



Jessica L Nunamaker  
Microbiologist/QA Officer

DOH#	PARAMETER	RESULT	Qualifier*	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>		per 100mL	mlp	SM9223 B	m_250211b	
3	E. COLI	<b>Absent</b>		per 100mL		SM9223 B	m_250211b	

If the sample is unsatisfactory you can get information on well disinfection at Washington State Department of Health:

WA DOH: <https://doh.wa.gov/community-and-environment/drinking-water/disinfection>

**NOTES:**

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

\*If data qualifiers are present, see accompanying Qualifier Definition report.