



ANALYTICAL REPORT

PREPARED FOR

Attn: Water Report
NW Natural Water Services, LLC
107 S Main St
Coupeville, Washington 98239

Generated 2/4/2026 6:39:04 PM

JOB DESCRIPTION

Saratoga 763000 - Compliance

JOB NUMBER

110-5692-1

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Authorization



Generated
2/4/2026 6:39:04 PM

Authorized for release by
Crystal Deighton, Admin Asst. I
Crystal.Deighton@et.eurofinsus.com
(360)757-1400

Client Sample Results

Client: NW Natural Water Services, LLC
Project/Site: Saratoga 763000 - Compliance

Job ID: 110-5692-1

Client Sample ID: S05

Date Collected: 01/28/26 10:00

Date Received: 01/29/26 15:42

Lab Sample ID: 110-5692-1

Matrix: Drinking Water

PWSID Number: 763000

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Arsenic	0.0047		0.0010	mg/L		02/04/26 16:50	1	NB

Action Limit Summary

Client: NW Natural Water Services, LLC
Project/Site: Saratoga 763000 - Compliance

Job ID: 110-5692-1

Client Sample ID: S05

Lab Sample ID: 110-5692-1

PWSID Number: 763000

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Arsenic	0.0047		mg/L	0.01	0.0010	200.8	Total/NA

Multiple WSI / ANALYSIS REQUEST

Client & Billing Information			
Report To: NW Natural Water Services	Bill To: KIN07		
Ship Address: 102 SW Terry Road	Address:		
City: Coupeville	St: WA	City:	St:
	Zip: 98239		Zip:
Phone: 360-226-5007/360-226-4745	Fax:	Phone:	
Email: wa_testing@nwnaturalwaterservices.com		P.O. #	
Contact: Jessica Zimmer			
Project Name: Saratoga Water District			

Page _ of _



110-5692.COC

ICAL

Main Lab (800-755-9295)
1620 S Walnut St, Burlington WA 98733
Bellingham (888-725-1212)
805 W Orchard Dr, Suite 4, Bellingham, WA 98225

1. Use ONE LINE PER SAMPLE LOCATION.
2. BE SPECIFIC IN TEST REQUESTS.
3. CHECK OFF ANALYSIS TO BE PERFORMED FOR EACH SAMPLE LOCATION.
4. ENTER NUMBER OF CONTAINERS PER SAMPLE LOCATION.

Compliance
Arsenic

Number of Containers:

SPECIAL SOURCE NUMBERS

12 DISTRIBUTION (THM/HAA)
16 BLENDED SAMPLE
33 STANDING WATER (P&Cu)
35 LAB COMPOSITE
00 DISTRIBUTION (BACTERIA)

**SPECIAL INSTRUCTIONS /
CONDITIONS ON RECEIPT**

[illegible]

DISAMPLIFIED/NOUSHED BY	DATE	TIME	RECEIVED BY	DATE	TIME
					
EDGE PU01 1/29/26 15:42					

CUSTODY SEALS INTACT
SAMPLE TEMP 4.6 C SATISFACTORY
EVIDENCE OF COOLING
SAMPLES RECEIVED INTACT
CHAIN OF CUSTODY & LABELS AGREE

YES ☒ ☐ ☐ ☐ ☐

NO ☐ ☐ ☐ ☐ ☐

N/A ☐ ☐ ☒

Chain of Custody Record

[illegible]