

1620 S Walnut Street, Burlington, WA 98233 / Tel: (360) 757-1400 / Lab ID No. C838

Select Inorganic Chemistry

Report of Analysis

Date Collected: (MM/DD/YY) 02/25/26	System Group Type: (circle one) A B Other:
Water System ID Number: 763000	System Name: Saratoga Water District
Lab Number / Sample Number: 094 / 64981	County: Island
Sample Location: Week 4	Source Number(s): (list all sources if blended or composited) 05
<u>Sample Purpose: (check appropriate box)</u> ☒ RC - Routine Compliance (satisfies monitoring requirements) ☐ C - Confirmation (confirmation of chemical result)* ☐ I - Investigative (does not satisfy monitoring requirements) ☐ O - Other (specify - does not satisfy monitoring requirements)	Date Received: (MM/DD/YY) 02/26/26 Date Analyzed: (MM/DD/YY) 03/04/26 Date Reported: (MM/DD/YY) 03/06/26 COMMENTS:
<u>Sample Composition: (check appropriate box)</u> ☒ S - Single Source ☐ B - Blended (list source numbers in "Source Numbers" field) ☐ C - Composite (list source numbers in "Source Numbers" field) ☐ D - Distribution Sample	<u>Sample Type: (check one)</u> ☐ Pre-treatment/Untreated (Raw) ☒ Post-treatment (Finished) ☐ Unknown or Other Sample Collected by: (name) J Dunbar Phone Number:
Send Report to: NW Natural Water Services, LLC 107 S Main St Coupeville, WA 98239	Bill to: (client name)

ANALYTICAL RESULTS

DOH #	ANALYTE	DATA QUALIFIER	RESULTS	SDRL	TRIGGER	MCL	UNITS	EXCEED MCL? (X if Yes)	DATE ANALYZED	METHOD/ INITIALS
0021	Chloride			20	--	250 ¹	mg/L			
0016	Conductivity			70	--	700 ¹	µmhos/cm			
0004	Arsenic		0.0038	0.001	0.010	0.010	mg/L		03/04/2026	200.8 / T8BB
0020	Nitrate-N			0.5	5.0	10.0	mg/L			
0008	Iron			0.1	--	0.3 ¹	mg/L			
0010	Manganese			0.01	--	0.05 ¹	mg/L			
0017	Turbidity			0.1	--	--	NTU	--		
0019	Fluoride			0.2	2.0	4.0	mg/L			
0014	Sodium			5	--	--	mg/L	--		
0022	Sulfate			50	--	--	mg/L	--		

NOTES:

***Confirmation:** Include the original lab number, sample number, and collection date of original sample in either comment section.

--No existing trigger or MCL value.

¹Secondary MCL (Established for aesthetic purposes, not health based).

ANALYTE: The name of the analyte being tested for.

DATA QUALIFIER: A symbol or letter to denote additional information about the result.

DOH#: Department assigned analyte number.

EXCEEDS MCL (Maximum Contaminant Level): Marked if the contaminant amount exceeds the MCL under chapters 246-290 and 246-291 WAC.

Please contact the department's drinking water regional office in your area to determine follow-up actions.

METHOD/INITIALS: Analytical method used. / Initials of the analyst that performed the analysis.

mg/L: milligrams per liter or parts per million.

NTU: Nephelometric turbidity units.

RESULT: The laboratory reported result.

SDRL (State Detection Reporting Limit): The minimum reportable detection of an analyte as established by the department.

TRIGGER: The department's drinking water response level. Systems with contaminants detected at concentrations in excess of this level may be required to take additional samples or monitor more frequently. Please contact the department's drinking water regional office in your area for further information.

µmhos/cm: micro ohms per centimeter. One micro ohm per centimeter is equivalent to one micro Siemen per centimeter (µS/cm).

LAB COMMENTS: