



ANALYTICAL REPORT

PREPARED FOR

Attn: Water Report
NW Natural Water Services, LLC
107 S Main St
Coupeville, Washington 98239

Generated 6/25/2026 10:09:15 PM

JOB DESCRIPTION

Saratoga Water District- 763000

JOB NUMBER

110-12473-1

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Authorization



Generated
6/25/2026 10:09:15 PM

Authorized for release by
Crystal Deighton, Project Manager
Crystal.Deighton@et.eurofinsus.com
(360)757-1400

Client Sample Results

Client: NW Natural Water Services, LLC
Project/Site: Saratoga Water District- 763000

Job ID: 110-12473-1

Client Sample ID: Saratoga - Week 2

Lab Sample ID: 110-12473-1

Date Collected: 06/17/26 15:36

Matrix: Drinking Water

Date Received: 06/19/26 15:46

PWSID Number: 763000

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst	
Arsenic	0.021		0.0010	mg/L		06/24/26 19:53	1	VB9B	

Action Limit Summary

Client: NW Natural Water Services, LLC
Project/Site: Saratoga Water District- 763000

Job ID: 110-12473-1

Client Sample ID: Saratoga - Week 2 Lab Sample ID: 110-12473-1
PWSID Number: 763000

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Arsenic	0.021		mg/L	0.01	0.0010	200.8	Total/NA

Page 6 of 6

- 1
- 2
- 3
- 4