



ANALYTICAL REPORT

PREPARED FOR

Attn: Water Report
NW Natural Water Services, LLC
107 S Main St
Coupeville, Washington 98239

Generated 6/3/2026 9:37:32 PM

JOB DESCRIPTION

Saratoga - 763000

JOB NUMBER

110-11487-1

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Authorization



Generated
6/3/2026 9:37:32 PM

Authorized for release by
Crystal Deighton, Project Manager
Crystal.Deighton@et.eurofinsus.com
(360)757-1400

Client Sample Results

Client: NW Natural Water Services, LLC
Project/Site: Saratoga - 763000

Job ID: 110-11487-1

Client Sample ID: Saratoga - Week 3

Lab Sample ID: 110-11487-1

Date Collected: 05/22/26 13:00

Matrix: Drinking Water

Date Received: 05/28/26 16:05

PWSID Number: 763000

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Arsenic	0.0068		0.0010	mg/L		06/03/26 15:04	1	T8BB

Action Limit Summary

Client: NW Natural Water Services, LLC
Project/Site: Saratoga - 763000

Job ID: 110-11487-1

Client Sample ID: Saratoga - Week 3
PWSID Number: 763000

Lab Sample ID: 110-11487-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Arsenic	0.0068		mg/L	0.01	0.0010	200.8	Total/NA

Multiple WSI / ANALYSIS REQUEST

Page _ of _

Client & Billing Information

Report To: NW Natural Water Services
 Ship Address: 102 SW Terry Road
 City: Coquille
 Phone: 360-226-5007/360-226-4745 Fax:
 Email: wa.testing@nwnaturalwaterservices.com
 Contact: Jessica Zimmer

Bill To: KIN07
 Address:
 City: St. Zip:
 Phone: P.O.#

110-11487 CO
 1620 S West
 Bellingham (888-743-1212)
 805 W Orchard Dr. Suite 4, Bellingham, WA 98225



INSTRUCTIONS

- USE ONE LINE PER SAMPLE LOCATION.
- BE SPECIFIC IN TEST REQUESTS.
- CHECK OFF ANALYSIS TO BE PERFORMED FOR EACH SAMPLE LOCATION.
- ENTER NUMBER OF CONTAINERS PER SAMPLE LOCATION.

Turn Around Time Requested

- ☒ STANDARD
☐ HALF-TIME (50% SURCHARGE)
☐ QUICKEST (100% SURCHARGE) (PHONE CALL REQ.)
☐ EMERGENCY (PHONE CALL REQUIRED)

Compliance
 Arsenic

SPECIAL SOURCE NUMBERS
 92 DISTRIBUTION (THM/HAA)
 98 BLENDED SAMPLE
 93 STANDING WATER (PB&Cu)
 95 L&S COMPOSITE
 00 DISTRIBUTION (BACTERIA)

SPECIAL INSTRUCTIONS /
 CONDITIONS ON RECEIPT

SYSTEM ID	SOURCE#	SAMPLE LOCATION	DATE	TIME	Number of Containers	?	TOTAL CONTAINERS
1 763000	S05	Saratoga - Week 3	5/22/26	1300	1		
2							
3							
4							
5							
6							
7							
8							
9							
10							

SAMPLED BY: JOSH BOWEN

PHONE:

FAX:

EMAIL:

CUSTODY SEALS INTACT
 SAMPLE TEMP 4.0 C SATISFACTORY
 EVIDENCE OF COOLING
 SAMPLES RECEIVED INTACT
 CHAIN OF CUSTODY & LABELS AGREE

DATE	TIME	RECEIVED BY	DATE	TIME
		YFW edge	5-28-26	1105

FORM: WSIinit_vwa.rpt

[illegible]