



ANALYTICAL REPORT

PREPARED FOR

Attn: Water Report
NW Natural Water Services, LLC
107 S Main St
Coupeville, Washington 98239

Generated 7/22/2026 2:28:18 AM

JOB DESCRIPTION

Saratoga Water District - 763000

JOB NUMBER

110-13698-1

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Authorization



Generated
7/22/2026 2:28:18 AM

Authorized for release by
Crystal Deighton, Project Manager
Crystal.Deighton@et.eurofinsus.com
(360)757-1400

Client Sample Results

Client: NW Natural Water Services, LLC
Project/Site: Saratoga Water District - 763000

Job ID: 110-13698-1

Client Sample ID: Saratoga - Week2 S05

Lab Sample ID: 110-13698-1

Date Collected: 07/13/26 13:33

Matrix: Drinking Water

Date Received: 07/14/26 16:03

PWSID Number: 763000

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Arsenic	0.023		0.0010	mg/L		07/20/26 17:56	1	VB9B

Action Limit Summary

Client: NW Natural Water Services, LLC
Project/Site: Saratoga Water District - 763000

Job ID: 110-13698-1

Client Sample ID: Saratoga - Week2 S05

Lab Sample ID: 110-13698-1

PWSID Number: 763000

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Arsenic	0.023		mg/L	0.01	0.0010	200.8	Total/NA

Multiple WSI / ANALYSIS REQUEST

Client & Billing Information			
Report To: NW Natural Water Services	Bill To: KIN07		
Ship Address: 102 SW Terry Road	Address:		
City: Coupeville	St: WA	Zip: 98239	City:
Phone: 360-226-5007/360-226-4745	Fax:	Phone:	St:
Email: wa.testing@nwnaturalwaterservices.com		P.O.#	Zip:
Contact: Jessica Zimmer			
Project Name: Saratoga Water District			

age _ of _



110-13698 COC

ICAL

TE

Main Lab (800-755-9295)
1620 S Walnut St, Burlington, WA 98233
Bellinham (888-725-1212)
805 W Orchard Dr. Suite 4, Bellinham, WA 98225

INSTRUCTIONS:

1. USE ONE LINE PER SAMPLE LOCATION.
2. BE SPECIFIC IN TEST REQUESTS.
3. CHECK OFF ANALYSIS TO BE PERFORMED FOR EACH SAMPLE LOCATION.
4. ENTER NUMBER OF CONTAINERS PER SAMPLE LOCATION.

STANDARD	Half-Time (50% SURCHARGE)	QUICKEST (100% SURCHARGE)	PHONE CALL REQUIRED	EMERGENCY (PHONE CALL REQUIRED)
☒	☐	☐	☐	☐

[illegible]

SPECIAL SOURCE NUMBERS

92 DISTRIBUTION (THM/HA)	92 DISTRIBUTION (THM/HA)
96 BLENDED SAMPLE	96 BLENDED SAMPLE
93 STANDING WATER (P&C)	93 STANDING WATER (P&C)
95 LAB COMPOSITE	95 LAB COMPOSITE
00 DISTRIBUTION (BACTERIA)	00 DISTRIBUTION (BACTERIA)

SYSTEM ID	SOURCE#	SAMPLE LOCATION	DATE	TIME	Com	Arse														Nu	SPECIAL INSTRUCTIONS / CONDITIONS ON RECEIPT		
1 763000	S05	Saratoga - Week 2	7-13-26	1:33Am	☒	☒	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	1			
2					☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐				
3					☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐				
4					☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐				
5					☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐				
6					☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐				
7					☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐				
8					☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐				
9					☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐				
10					☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐				
SAMPLED BY: JAGUS & LINDA					PHONE:		FAX:		EMAIL:												? TOTAL CONTAINERS		

DISAMPAK BERKUNCI DIBY	DATE	TIME	RECEIVED BY	DATE	TIME

EDGE RECIO 7/14/26 1603

CUSTODY SEALS INTACT

SAMPLE TEMP. 0.1 °C SATISFACTORY

EVIDENCE OF COOLING

SAMPLES RECEIVED INTACT

CHAIN OF CUSTODY & LABELS AGREE