



# ANALYTICAL REPORT

## PREPARED FOR

Attn: Water Report  
NW Natural Water Services, LLC  
107 S Main St  
Coupeville, Washington 98239

Generated 8/26/2026 2:52:24 AM

## JOB DESCRIPTION

Saratoga - Arsenic

## JOB NUMBER

110-15509-1

# Eurofins Washington

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

## Authorization



Generated  
8/26/2026 2:52:24 AM

Authorized for release by  
Crystal Deighton, Project Manager  
[Crystal.Deighton@et.eurofinsus.com](mailto:Crystal.Deighton@et.eurofinsus.com)  
(360)757-1400

## Client Sample Results

Client: NW Natural Water Services, LLC  
Project/Site: Saratoga - Arsenic

Job ID: 110-15509-1

**Client Sample ID: Saratoga - Arsenic - Week 2**

**Lab Sample ID: 110-15509-1**

**Date Collected: 08/19/26 10:46**

**Matrix: Drinking Water**

**Date Received: 08/19/26 14:52**

**PWSID Number: 763000**

**Method: 200.8 - Metals (ICP/MS)**

| Analyte | Result | Qualifier | RL     | Unit | D | Analyzed       | Dil Fac | Analyst |
|---------|--------|-----------|--------|------|---|----------------|---------|---------|
| Arsenic | 0.035  |           | 0.0010 | mg/L |   | 08/24/26 16:14 | 1       | T8BB    |

## Action Limit Summary

Client: NW Natural Water Services, LLC  
Project/Site: Saratoga - Arsenic

Job ID: 110-15509-1

**Client Sample ID: Saratoga - Arsenic - Week 2**

**Lab Sample ID: 110-15509-1**

**PWSID Number: 763000**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

| Analyte | Result | Qualifier | Unit | EPAMCL<br>Limit | RL     | Method | Prep Type |
|---------|--------|-----------|------|-----------------|--------|--------|-----------|
| Arsenic | 0.035  |           | mg/L | 0.01            | 0.0010 | 200.8  | Total/NA  |

1620 S Walnut Street  
Burlington, WA 98233  
Phone (360) 757-1400

## Chain of Custody Record



## Environment Testing

[illegible]

1620 S Walnut Street  
Burlington, WA 98233  
Phone 360-757-1400 Fax 360-999-9999



## Environment Testing

~~Page 6 of 6~~